AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Primary Flooring Pty Ltd

380 Dohertys Road
Truganina VIC 3029

Test Number : 21-Issue Date : 15/

21-003778

Print Date

15/09/2021 15/09/2021

Sample Description

Clients Ref :

"Platinum Plush, Manufacturer: Victoria Carpets"

Cut pile carpet tested on Dunlop Supergreen Underlay

Colour : Beige End Use : Flooring

Nominal Composition: 80% Wool, 20% Polyester Nominal Mass per Unit Area/Density: 49oz/yd2

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Radiant Heat Source
Date of Sample Arrival

23-07-2021

Date Tested

14-09-2021

CHF	Value
Length	
Width	

1 2.8 3.4 2.8

Mean 2.8

2.8 kW/m²

kW/m²

%.min

Smoke Value

Length

Width

1 244

219

2 254 3 238

3

2.8

Mean

245 %.min

Melting

53150

Yes

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of $23\pm2^{\circ}$ C and relative humidity of $50\pm5\%$ for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

HF30 not reported as flame out time occurred before 30 minutes.

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved

249407

NATA

Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Fiona McDonald

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc.(Hons)

Page 1 of 2

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Primary Flooring Pty Ltd

380 Dohertys Road Truganina VIC 3029 **Test Number** : 21-003778

Issue Date

Print Date : 15/09/2021

15/09/2021

Each specimen was loose laid over Dunlop Supergreen underlay and 6mm thick fibre reinforced cement board and clamped prior to testing.

249407 53150 Page 2 of 2

 Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc.(Hons)