

CUSTOMER REFERENCE
SOUNDWAVE 1211

Sample description as provided by customer

Mass/unit area **16 oz/yd²**

Construction Details **Tufted** Secondary Backing **TILE BACKING**

Style **Loop Pile**

The Samples Tested Were Modular Carpet

Order No. 50930

Pile Fibre Content **100% SOLUTION DYED NYLON**

Colour **Charcoal/Black**

Pile Height / mm

TEST METHOD AS/ISO 9239.1 2003 Reaction To Fire Tests For Floorings Part 1 Determination of the Burning Behaviour Using a Radiant Heat Source. As required by specification C1.10 of the Building Code of Australia.

The test values relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be the sole criterion for assessing the potential fire hazard of the product. Clause 9 of AS/ISO 9239 Part 1.

Conditioning as specified in BS EN 13238.2001

Sample submitted Date **Oct 2013**

Test Date **29 Oct 2013**

ASSEMBLY SYSTEM: DIRECT STICK (Details Below).

The floor covering was directly stuck to the substrate using **Water Based Surface Contact** adhesive.

Substrate: Non-Combustible

Substrate - 6mm Fibre Reinforced Cement Board to simulate a Non-Combustible Flooring.

The Holding Torque on Specimen Frame was 2Nm.

Initial Test Specimen 1 Length Direction Critical Radiant Flux **9.9 kW/m²**
Specimen 1 Width Direction Critical Radiant Flux **9.0 kW/m²**
Full tests carried out in the **Width** Direction



SPECIMEN	Width #1	Width #2	Width #3	Mean
Critical Radiant Flux (kW/m ²)	9.0	9.6	9.6	9.4
Smoke Development Rate (%.min)	112	112	121	115

The values quoted below are as required by Specification C1.10 Fire Hazard Properties (Floors) of the Building Code of Australia. The Critical Radiant Flux quoted is the value at Flame-Out/Extinguishment (BCA General Provisions A1.1).

MEAN CRITICAL RADIANT FLUX **9.4 kW/m²**

MEAN SMOKE DEVELOPMENT RATE **115 percent-minutes**

OBSERVATIONS: **The samples shrunk away from the heat source ,ignited and burnt a very short distance**

 ACCREDITED FOR TECHNICAL COMPETENCE	M. B. Webb Technical Manager	
	DATE: 29/10/2013	
	Performance & Approvals Testing No. 15393	
	Accredited for compliance with ISO/IEC 17025.	

PAGE 1 of 2

Clause 9 of AS/ISO 9239 Part 1

The values on Page 2 have no relevance to the Code.

1004 04 09